

**KANSAS DEPARTMENT OF HEALTH AND ENVIRONMENT
WASTEWATER INCIDENT REPORT FORM**

Definitions are available at <http://www.kdheks.gov/water/tech.html>

Collection In-Plant In-Plant Spill
System Bypass Diversion Upset Flow Through

1. FACILITY NAME: City of Parsons Kansas Permit # M-NE55-OO02
2. Within 24 hours of discovery, notify the KDHE Central Office (email – cseeds@kdheks.gov), (fax 785.296.0086), (telephone 785.296.5517) or your local KDHE district office. Written notification is required within 5 days of discovery. If the incident is not corrected within 5 days, send a written notification to KDHE indicating the status. This form is to be sent to KDHE when the incident ends.

**IF THE INCIDENT IS AFTER HOURS AND REPRESENTS A SIGNIFICANT
PUBLIC HEALTH THREAT CALL 785.296.1679 IMMEDIATELY**

KDHE Person Contacted: Shelly Date: 5/22/17 Time: 2:30 PM

3. Date Incident Discovered: 5/20/2017 Time: 2:55 AM

4. Date Incident Ended: 5/21/2017 Time: 4:26 AM

5. Total estimated gallons bypassed, spilled, or routed through failed equipment for all locations on this form: 1,822,000

6. If rainfall induced event, approximate inches of rainfall 1.75

If multiple locations listed below due to rain event, check here

7. Incident Location: (check all that apply)

- | | |
|---|--|
| <input checked="" type="checkbox"/> Plant | <input type="checkbox"/> City Collection Line (Line Break / Joint) |
| <input type="checkbox"/> Lift/Pump Station | <input type="checkbox"/> Private Sewer Line |
| <input checked="" type="checkbox"/> Peak Flow Basin | <input type="checkbox"/> Basement |
| <input type="checkbox"/> Manhole(s) | <input type="checkbox"/> Other (specify below) |

Identify **All** Incident Locations by Name, Street Address or Manhole Number as appropriate.

8. Cause of Incident:

- | | |
|---|---|
| <input type="checkbox"/> Intentional Bypass for Repair/Construction | <input checked="" type="checkbox"/> Equipment Failure |
| <input checked="" type="checkbox"/> Excessive Rainfall, Snow Melt | <input type="checkbox"/> Control System Failure |
| <input type="checkbox"/> Unplanned Construction Related Break | <input type="checkbox"/> Power Related Failure |
| <input type="checkbox"/> City Line Break (Not Construction Related) | <input type="checkbox"/> Operations Related Failure |
| <input type="checkbox"/> City Line Blockage | <input type="checkbox"/> Maintenance Related Failure |
| <input type="checkbox"/> Private Line Break | <input type="checkbox"/> Vandalism |
| <input type="checkbox"/> Private Line Blockage | <input type="checkbox"/> Other |
| <input type="checkbox"/> Lagoon High Level | |

Additional explanation of reason for Incident: (use additional page if necessary)

We have installed one new pump and it is working but not with a VDF, so it is being used sparingly. Pump #3 is completely unusable, the shaft is broken. Out of the three existing pumps we only have one pump working. We are waiting on the VFD's to show up to install the other two new pumps to be able to put them into operation.

9. Corrective Action, if any: (use additional page if necessary)

Name: Derek Clevenger Date: 5-22-17

Title: Director of Utilities Phone: (620) 421-7020

When Completed, E-mail to: cseeds@kdheks.gov
Kansas Department of Health & Environment – Attn: Chris Seeds

Or Mail to: 1000 SW Jackson St., Suite 420, Topeka , KS 66612-1367
Fax 785.296.0086

REV 20150505